

Supply and Return Ducts in Attics and Other Unconditioned Spaces:

- All Supply and Return Ducts shall be insulated R-8 Minimum.

Exception: Ducts or portions thereof located inside the Building Envelope shall not be required to be Insulated.

Exhaust Ducts:

- Exhaust Ducts with the potential of Condensation (Kitchen, Dryer, Bath fan) shall be insulated R-4.2 Minimum.

Hot Water Piping shall be Insulated R-3 Minimum in the following locations:

- 1) Hot Water Supply Piping 3/4" and Larger
- 2) Serving More than One Dwelling
- 3) From the Water Heater to Distribution Manifold
- 4) Located under a concrete slab
- 5) Buried underground
- 6) Supply and Return on a Recirculation System
(**Exception:** On Demand Recirculation Systems)

Mechanical Contractors have until 6 30 2017 to use on hand stock of lower insulation values for Supply and Return Ducts.